



KARNATAKA STATE FIRE AND EMERGENCY SERVICES
OFFICE OF THE FIRE STATION OFFICER
FIRE STATION HARIHARA
Telephone : 08192-242601



ಕ್ರ.ಸಂ:97/ಅತಾಅ/ಹಲತಾ/2020
97/FSO/HFO/2020

DATE/30/07/2020

HYDRAULIC PRESSURE TESTING CERTIFICATE REPORT
KARNATAKA STATE FIRE AND EMERGENCY SERVICES
OFFICE OF THE FIRE STATION OFFICER
FIRE STATION HARIHARA
THAIBA GREENWAYS SCHOOL HARIHARA

Two no's ABC stored pressure type fire extinguishers(5 kg) which are belonged to THAIBA GREENWAYS SCHOOL HARIHARA has been subjected to 300 pound water pressure on 29/07/2020 and the obtained testing results are shown below in the tabular coloumn.

The validity period of the Two no's ABC stored pressure type fire extinguishers is dated on 30/07/2020 to 29/07/2021.

On completion of the above validity period these Two no's ABC stored pressure type fire extinguishers must be again subjected to the hydrolic pressure test.

SL	Model of fire extinguisher	No's	Result
01	ABC DRY CHEMICAL POWDER	02	satisfied
	Total extinguisher-02 no's		

TO

THAIBA GREENWAYS SCHOOL
HARIHARA

Sudhakar 30-07-20
ಅಗ್ನಿಶಾಮಕ ವಾಹಾಧಿಕಾರಿ
ಅಗ್ನಿಶಾಮಕ, ಉ.ಆ.ಒ.
ಹರಿಹರ-577501